

Static lines and anchor points (Drill,Glue,Frict.)

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 02/10/2020						
1	Carry out an inspection of the system (steel rope or rail system).				Y	
2	Carry out a visual inspection of the parent structure for any modifications, damage or deterioration e.g. corrosion, cracking etc.				Y	
3	Check the condition and correct operation of the line tensioners and line energy absorbers (horizontal lines).				Y	
4	Check the integrity and condition of the cable, rails and all fittings.				Y	
5	Check the condition of the rigid rails especially: a) Connections are intact (brackets, plates, clips, nuts etc.). b) Connections are tight. c) Connections are free from corrosion, dirt, grit etc. d) Condition of end stops.				Y	
6	Check the condition and correct function of permanently installed mobile attachment devices.				Y	
7	Check for the presence of contaminants that may affect the operation of the system.				Y	
8	Ensure the inspection plate is legible and located at each entry point.				Y	
9	Check the tag for the date of the last inspection and update.				Y	
10	Load (proof) test all the anchor points in accordance with AS1891.4 clause 3.1.2(g). See the Special Comments for more information.				Y	
11	Record the results in the logbook and submit a customer service report to the FMSP.				Y	

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia  
Department of Planning,  
Transport and Infrastructure

Download Date: 22/12/2020

## Special Comments and Technical Data

---

THIS TDS B32 IS FOR DRILLED, GLUED OR FRICTION TYPES OF STATIC LINES AND ANCHOR POINTS. FOR STRUCTURAL TYPE ANCHORS REFER TO TDS B44. IT APPLIES TO ANCHOR POINTS ON EXISTING STRUCTURES ONLY (CONSTRUCTION ITEMS ARE NOT APPLICABLE).

### D SERVICE ANNUAL

SERVICE FREQUENCIES AND ACTIVITIES MAY VARY DEPENDING ON SITE CONDITIONS AND MANUFACTURER'S RECOMMENDATIONS WHICH MUST BE FOLLOWED.

THE SERVICE IS TO BE CONDUCTED BY A HEIGHT SAFETY EQUIPMENT INSPECTOR AND DONE IN ACCORDANCE WITH AS1891.2, AS1891.4, AND AS4488.2.

THE LOAD TESTS OF THE ANCHORS ARE TO BE PERFORMED IN ACCORDANCE WITH AS1891.4 AND AS4488.2 (AS FOR DRILLED IN ANCHORS). THE TEST IS AN AXIAL PULL OUT (PROOF) TEST TO 50% OF THE DESIGN ULTIMATE ANCHORS STRENGTH AS SPECIFIED IN AS1891.4 TABLE 3.1 AND UNDERTAKEN IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.

ALL SERVICE WORKS MUST BE CARRIED OUT IN ACCORDANCE WITH THE FOLLOWING LEGISLATION AND CODE:

- \* WH&S REGULATIONS. AND SPECIFICALLY REGULATION 78: 'MANAGEMENT OF RISK OF FALL'.
- \* WH&S REGULATIONS. AND SPECIFICALLY REGULATION 79: 'SPECIFIC REQUIREMENTS TO MINIMISE RISK OF FALL'.
- \* SAFE WORK AUSTRALIA'S 'MANAGING THE RISK OF FALLS AT WORKPLACES' CODE OF PRACTICE'.

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

*For more information please contact the applicable Facilities Management Service Provider.*



**Government of South Australia**  
Department of Planning,  
Transport and Infrastructure

**Download Date:** 22/12/2020

# Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.