

Dishwasher - Hard Wired (Hobart)

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 20/07/2018						
1	Check strainers on all supply lines.			Y		
2	Check doors, door seals, handles, strainer pans.			Y		
3	Check rack tracks, suspension straps, rack drive system.			Y		
4	Check pump filters.			Y		
5	Check heating elements for insulation resistant wash/rinse.			Y		
6	Check tank, drain, overflow, pumps.			Y		
7	Check piping for leaks and foreign objects.			Y		
8	Check tank filling, water level and water temps, adjust.			Y		
9	Check pump motors for correct rotation, leakage & conditions.			Y		
10	Clean wash & rinse arm nozzles.			Y		
11	Check water pressures including pump conditioners.			Y		
12	Check all shut-off valves, solenoid valves, steam traps.			Y		
13	Check all safety & pressure reducing valves.			Y		
14	Check all switches for operation & leakage.			Y		
15	Check motor leads, contactors, overloads, switches.			Y		
16	Check control lamps & all electrical safety devices.			Y		
17	Check electrical connections & tighten all cable fasteners.			Y		
18	Check conveyor slip clutch alignment and tension.			Y		
19	Check conveyor chain drive tension, grease chain and adjust.			Y		
20	Check operation of conveyor trip/hood, door switches.			Y		
21	Check rinse actuation mechanism for operation.			Y		
22	Check motor inlet screens and ensure free from obstruction.			Y		
23	Check manual and automatic timer operation.			Y		
24	Check chemical supply for leaks.			Y		
25	Inspect chemical squeeze tubes - replace if necessary.			Y		
26	Check steam extractor vanes and/or dryer fan rotation.			Y		
27	Check condenser/dryer system for correct operation.			Y		
28	Check operation and listen to any gear or motor bearing noise.			Y		
29	Check visual and audible warnings are functioning.			Y		
30	Check condition of racks, cutlery baskets.			Y		
31	Check machine for proper condition.			Y		

**Disclaimer** - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia  
Department of Planning,  
Transport and Infrastructure

Download Date: 22/12/2020

Dishwasher - Hard Wired (Hobart)

Last Issue Date: 20/07/2018		Type Of Service				
		A	B	C	D	E
Activity						
32	Indicated wash temperature certified correct to within: +/-1 degC - Against a NATA Calibrated Instrument (wash).			Y		
33	Indicated rinse temperature certified correct to within: +/-1 degC - Against a NATA Calibrated Instrument (rinse).			Y		
34	Record service and any repairs in the log book.			Y		

**Special Comments and Technical Data**

---

C SERVICE 3 MONTHLY  
 SERVICING IS TO BE DONE IN ACCORDANCE WITH THE  
 MANUFACTURER'S RECOMMENDATIONS AND:  
 - HEALTH FSP TEMPLATE FOR HOSPITALS MAINTENANCE AND  
 CALIBRATION (3.22 C21, C22).  
 - SA HEALTH GUIDE FOR CALIBRATION OF TEMPERATURE MEASURING  
 EQUIPMENT TEMPLATE FOR HOSPITALS.  
 - AS ISO 22000.  
 SERVICE TO BE DONE BY A COMPETENT TECHNICIAN.

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

*For more information please contact the applicable Facilities Management Service Provider.*



Government of South Australia  
 Department of Planning,  
 Transport and Infrastructure

**Download Date:** 22/12/2020

# Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.