

Security System - Movement Detection

Last Issue Date: 16/12/2016		Type Of Service				
		A	B	C	D	E
Activity						
1	Check installation against records, record and report any discrepancy.				Y	
2	Check and test the operation of all detection devices. Detectors are to be walk tested and their response compared to the published detection pattern.				Y	
3	Check operation of all control equipment.				Y	
5	Check the operation of all activating outputs which respond to an alarm condition.				Y	
6	Check, in cooperation with the monitoring station, the operation of any communication equipment.				Y	
7	Check system voltage under full load conditions with the mains supply OFF for not less than 10 minutes. Ensure that the output under such conditions of all standby batteries and power supplies is not less than 95 percent of rated voltage.				Y	
8	Check and record charger output voltage to battery.				Y	
9	Check battery: a) Terminals for tightness, cleanliness and corrosion. b) Enclosure for cleanliness and corrosion.				Y	
10	Check the condition of all equipment for damaged, stressed or heated components.				Y	
11	Check all visible wiring, conduits, connectors and manual interfaces for damage.				Y	
12	Check all equipment for proper ventilation.				Y	
13	Ensure all switches are set to normal position, mains power is on and connected to system.				Y	
14	Record all results in a log book.				Y	

Special Comments and Technical Data

C SERVICE 6 MONTHLY (IF REQUESTED)
 D SERVICE ANNUAL (FOR DECD SITE)
 BEFORE ANY TESTS ARE CARRIED OUT, NOTIFY MONITORING STATION.
 DO NOT DISCONNECT, BRIDGE OR REMOVE ANY DEVICE WITHOUT NOTIFYING THE CLIENT, MONITORING STATION AND ENTERING IT INTO THE RECORDS BOOK WITH PRECISE REASONS FOR THE ACTION.
 SPECIALIST ELECTRONICS CONTRACTOR REQUIRED FOR THIS WORK.
 THE SERVICING IS TO BE DONE IN ACCORDANCE WITH THE MANUFACTURERS WRITTEN INSTRUCTIONS WHICH MAY HAVE ADDITIONAL &/OR ALTERNATIVE SERVICING REQUIREMENTS &/OR SERVICING FREQUENCIES.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.