

Security Control System - INET Type

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 07/10/2020						
1	CCTV: Confirm that the documentation corresponds with actual site locations of all CCTV equipment. Report on the extent of any discrepancies and if evident, update the documentation and provide to the FMSP.				Y	
2	Review the CCTV installation and confirm that the purpose and objectives are still valid for the site. Notify the FMSP in writing of any recommended alterations.				Y	
3	Confirm that video camera/s are fully operational and rectify any issues identified.		Y	Y	Y	
4	Confirm the CCTV camera Pan / Tilt / Zoom operations where applicable. Rectify any issues identified.		Y	Y	Y	
5	Inspect all CCTV camera connectors and controls for damage. Rectify any issues identified.		Y	Y	Y	
6	Check video camera/s for proper ventilation. Clean any dust and debris from ventilation openings.		Y	Y	Y	
7	Test and record the output voltages of CCTV system power supplies. Replace any faulty equipment.		Y	Y	Y	
8	Confirm that all CCTV system receiver / drivers are operating correctly. Replace any faulty equipment.		Y	Y	Y	
9	Clean domes, lenses, housing windows and interior of housing.		Y	Y	Y	
10	Verify DVR recording on all channels. Notify the FMSP of any DVR operational issues or failures.		Y	Y	Y	
11	ACCESS CONTROL, SECURITY & DURESS SYSTEM EQUIPMENT: Confirm the operation of all access control audible and visual alarm devices. Rectify any issues and record any modifications in the logbook.			Y	Y	
12	Inspect door locks for alignment / operation / heat / diode / terminations & alignment. Rectify any issues identified.			Y	Y	
13	Inspect card readers for tampering / operation / integrity and verify readings. Notify the FMSP in writing of any evidence of tampering observed. Rectify any issues identified.			Y	Y	
14	Confirm the operation of all access control read switches and motion detectors. Rectify any issues identified.			Y	Y	
15	Test the operation and integrity of duress alarms and push buttons. Rectify any issues identified.			Y	Y	
16	Test the operation of HLI inputs received from the Building Management System. Notify the FMSP of any interface issues.			Y	Y	
17	If applicable, test and verify the operation of the pager alarms through the access control system.			Y	Y	
18	Backup the system.			Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Security Control System - INET Type

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 07/10/2020						
19	Backup the user data.			Y	Y	
20	Backup the user reports.			Y	Y	
21	Check the inlet against records and report and record any discrepancies. Rectify any issues identified.			Y	Y	
22	Test the access control system communications links and verify that they are operational. Rectify any issues identified.			Y	Y	
23	Test the operation of all additional access control equipment and accessories. Rectify any issues identified.			Y	Y	
24	Verify the operations of diagnostic LEDs on circuit boards. Replace any faulty circuit boards.			Y	Y	
25	Confirm that the system resumes normal operation upon restoration of power after a simulated power failure on the control panel.			Y	Y	
26	Confirm the system's memory retention once restored after a simulated power. Notify the FMSP of any major equipment failures and rectify issues where possible.			Y	Y	
27	Inspect connections and confirm that there is good electrical contact between terminals on all LAN and Field devices.				Y	
28	Confirm that the system power supply voltage is adequate. Replace any faulty power supplies.				Y	
29	Inspect the system power supplies for heat build-up and identify the cause if evidence is present. Rectify any issues.				Y	
30	<p>POWER SUPPLY AND STANDBY BATTERY SYSTEM:</p> <p>a) Test and record the charger output voltage to the battery for each module. Confirm that the charger voltage is correct for the battery type. Report any discrepancies to the FMSP.</p> <p>b) Replace the battery if the system is indicating a low battery status.</p> <p>c) Confirm the system voltage under full load conditions with the mains supply OFF for no less than 10 minutes or the site-specific backup duration.</p> <p>d) Ensure that the output under such conditions of all standby batteries and power supplies is not less than 95 percent of rated voltage for the duration of the test. Replace the battery with an equivalent or larger battery as appropriate if the test is failed.</p> <p>e) Inspect the battery terminals for tightness, cleanliness and corrosion.</p> <p>f) Replace any blown or corroded fuses.</p> <p>g) Replace the batteries at the frequency recommended by the manufacturer or as required from the testing and inspection.</p> <p>h) Inspect the battery enclosure for signs of corrosion and replace if necessary. Clean the enclosure from any dust / dirt accumulation.</p> <p>Note: If the battery is replaced, mark the date in a suitable location (battery or container).</p>				Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Security Control System - INET Type

Last Issue Date: 07/10/2020		Type Of Service				
		A	B	C	D	E
Activity						
31	Ensure that all emergency service contact information is up to date. Record the results in the logbook and submit a complete customer service report to the FMSP.		Y	Y	Y	

Special Comments and Technical Data

B SERVICE 3 MONTHLY (THIS SERVICE MAY NOT BE NECESSARY IF REMOTE DIAGNOSTICS ARE AVAILABLE.)
 C SERVICE 6 MONTHLY (THIS SERVICE MAY NOT BE NECESSARY IF REMOTE DIAGNOSTICS ARE AVAILABLE.)
 D SERVICE ANNUAL

SERVICE ACTIVITIES AND FREQUENCIES MAY VARY DEPENDING ON MANUFACTURER'S RECOMMENDATIONS AND SITE CONDITIONS.

BEFORE ANY TESTS ARE CARRIED OUT, NOTIFY THE MONITORING STATION.
 DO NOT DISCONNECT, BRIDGE OR REMOVE ANY DEVICE WITHOUT NOTIFYING THE SITE REPRESENTATIVE, MONITORING STATION & RECORDING IT IN THE LOGBOOK / CUSTOMER SERVICE REPORT WITH THE EXACT REASONS.

A SYSTEM RECORD IS TO BE PROVIDED WITH ALL SYSTEM MALFUNCTIONS, MAINTENANCE ACTIONS AND DETAILS OF ANY MODIFICATIONS OR ADDITIONS TO THE ACCESS CONTROL SYSTEM.

A SPECIALIST ELECTRONICS SUB-CONTRACTOR IS REQUIRED FOR THIS SERVICE WHO IS COMPETENT TO UNDERTAKE THE SERVICE FOR THE SPECIFIC SYSTEM AND CONFIGURATION.

APPLICABLE LEGISLATION AND STANDARDS: WH&S REGULATIONS, AS2201.1, AS4806.1, AS4806.2, AS/NZS IEC60839.11.2.

FOR Combined Security, Fire, Duress and Access Control SYSTEMS REFER TO TDS ET45.
 FOR Combined Security, Duress, Access Control Systems REFER TO TDS ET65.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.