

Fire Hydrant - D & E Service

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 22/02/2019						
1	Check that any previous defects and non-conformances have been attended to and recorded.				Y	Y
2	Water supply and backflow prevention stop valves, isolating valves and underground key operated valves: a) Verify valves are open, secure in the open position and correctly labelled; and b) Record the number of valves checked: water supply _____ backflow prevention _____ isolating _____ key operated _____				Y	Y
3	Check the hydrant valves (above ground): a) Are accessible; b) Have hand wheels that are securely fitted; and c) Blanking caps (where fitted) are in good condition.				Y	Y
4	Check the hydrant valves (below ground): a) Are accessible; b) Blanking caps (where fitted) are in good condition; c) Cover plate for ease of operation; and d) Are not leaking.				Y	Y
5	Check that all hydrant connection points are compatible with local brigade requirements.				Y	Y
6	Hydrant hose (where fitted): Check that all branch pipes, nozzles and hose couplings are in good condition, compatible with the hydrant valves and properly stowed.				Y	Y
7	Foam concentrate and loose equipment (where provided): a) Check the items in the cabinet comply with the contents list; b) Check the items are compatible and in good condition; c) Remove any incompatible or extraneous materials; d) Check the foam concentrate containers are in good condition, the seals are intact and the labels are legible; and e) Check the cabinet signage is clear and legible.				Y	Y
8	Hydrant cabinets: a) Check all for accessibility, for clear, correct signage & good condition; and b) Check cabinets are clear of extraneous materials.				Y	Y
9	Pressure reducing / Pressure limiting valves: Verify pressure readings for the pressure reducing and pressure limiting valves.				Y	Y
10	Block Plan and Pressure Gauge Schedule (where required): Check for legibility and visibility.				Y	Y
11	Hydrant Valves (Above and Below Ground): Partially open ALL hydrant valves in the system and prove the presence of water at each point.				Y	Y

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Fire Hydrant - D & E Service

Last Issue Date: 22/02/2019		Type Of Service				
		A	B	C	D	E
Activity		A	B	C	D	E
12	Hydrant Water Supply Valves: a) Operate (2 full turns) ALL valves - above ground, underground key operated valves and subsidiary stop valves - ensuring they are all fully open and where applicable, secured in the open position; b) Check labelling is correct; and c) Record the number of valves checked: water supply _____ backflow prevention _____ isolating _____ key operated _____				Y	Y
13	Valve Position Indicators: Verify they are securely mounted and indicate correctly.				Y	Y
14	Valve Monitors (where fitted): a) Test each one by closing and re-opening the valve; and b) Verify the correct position at the CIE.				Y	Y
15	Non-Return Valves: a) Verify they are ALL operating freely; and b) Are ALL seating correctly.				Y	Y
16	Hydrant Hose Fittings and Equipment (if fitted): Check and ensure the waterways are unobstructed and in good condition.				Y	Y
17	Undertake a Pressure-reducing Station Test: a) Operate and verify readings from pressure-reducing valves and record: _____ kPa. b) Operate and record the pressure at the pressure relief valves and record: _____ kPa.				Y	Y
18	Water Supply Proving Test: Undertake a Test for each water supply zone verifying that the system flow & pressure requirements meet the design criteria using either a: a) Fixed Flow Meter Test Facility - for each ZONE provide the: - Static Supply Pressure (kPa) and Flowing Pressure (kPa). OR, from the most hydraulically disadvantaged hydrant valve: b) Portable Test Apparatus - for each ZONE provide the: - Water Flow (L/s) and Pressure (kPa) and No of hydrants.				Y	Y
19	Check the Water Supply Strainers/Screens and clean the Suction Inlet Strainers.				Y	Y
20	Interface and Control Test (Refer TDS F39): A functional system test with other interfaced fire systems is to be done in accordance with AS1851 scheduled using F39: Interface Testing of Fire Protection Systems. Refer Special Comments.				Y	Y
21	Undertake a survey of the overall hydrant installation looking for any damage.				Y	Y
22	Check there are no occupancy changes applicable to the hydrant design.				Y	Y
23	Check the site documentation - block plans, emergency instructions and pressure				Y	Y

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Fire Hydrant - D & E Service

Last Issue Date: 22/02/2019		Type Of Service				
		A	B	C	D	E
Activity						
	schedules comply with AS2419.1.					
24	Drain and Test Valve Washers: a) For Screw-down Valves examine the seatings and fit new washers; and b) For Packed Gland Valves fit new gland packing.					Y
25	Stop Valves: Fit new gland packings and lubricate the spindles.					Y
26	Hydrant Valves: Fit new seatings to all valves & lubricate the spindles.					Y
27	Water Supply Non-return Valves: Renew water supply non-return valve seatings and gaskets.					Y
28	Pressure Gauges: Check all gauges against a calibrated gauge.					Y
29	Record the results in the log book.				Y	Y

Special Comments and Technical Data

D SERVICE ANNUAL / E SERVICE 5 YEARLY
 THIS IS A SPLIT SERVICES TDS & IS ONLY TO BE USED FOR SITES
 SELECTED BY THE FACILITY MANAGER.
 REFER F25B FOR THE C SERVICE & F25 FOR THE PRIMARY TDS.
 TESTING & SERVICING TO BE DONE IN ACCORDANCE WITH AS1851.
 APPLICABLE LEGISLATION: MINISTER'S SPEC. SA 76 (2015).
 OBTAIN SITE APPROVAL PRIOR TO TESTING OF THE SYSTEMS.
 THE ANNUAL INTERFACE TESTING (ACTIVITY 20) IS TO BE DONE UNDER
 TDS F39 WHICH HAS COMMENTS ON THE SCHEDULING ARRANGEMENTS.
 ENSURE THERE IS NO DUPLICATION OF SERVICES.
 REFER F25A FOR THE FIRE BOOSTER SERVICING (IF APPLICABLE),
 F38 FOR FIRE PUMPSETS & F40 FOR WATER STORAGE TANKS.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.