

Vertical Platform Lift

Activity		Type Of Service				
		A	B	C	D	E
1	Check all functions and their controls for speed, smoothness of operation and limits of motion.			Y	Y	
2	Check all emergency and safety devices including interlocks, emergency stops and emergency lowering devices.			Y	Y	
3	Check base or ground controls including the provisions for overriding of upper controls.			Y	Y	
4	Check all chain and cable mechanisms for adjustment, wear and damage.			Y	Y	
5	Lubricate all moving parts in accordance with the manufacturer's instructions.			Y	Y	
6	Inspect filter/s elements and fluid levels (if applicable).			Y	Y	
7	Visually inspect structural members and welds.			Y	Y	
8	Visually inspect and undertake measurement checks as necessary, of critical components such as: brakes, gears, fasteners, pins, shafts, wire ropes, sheaves, locking devices, all guard-rails and guarding, all attachments and connections, electrical contactors and all ancillary equipment.			Y	Y	
9	Check signage, including warning signs, decals and control markings.			Y	Y	
10	Check for corrosion and general condition of the lift for any damage.			Y	Y	
11	Ensure the space below the platform is clear of leaves & obstructions.			Y	Y	
12	Check wear on tyres and for damage to the wheel rims.			Y	Y	
13	Check the condition of the battery back-up for the emergency signal and the two-way communication system (if applicable).			Y	Y	
14	Replace the oil if required/applicable.				Y	
15	Carry out an inspection to statutory requirements & leave the report in the log book. The report is to state whether the installation is safe to operate or not. Provide a copy of the report to the Facility Manager.				Y	
16	Record all results in the log book.			Y	Y	

Special Comments and Technical Data

C SERVICE 3 OR 6 MONTHLY. FREQUENCY TO SUIT SITE REQ'MENTS.
 D SERVICE ANNUALLY.
 THIS IS A GENERIC SCHEDULE FOR SERVICING REQUIREMENTS FOR THIS PLANT. THE SERVICING IS TO BE DONE IN ACCORDANCE WITH THE MANUFACTURER'S WRITTEN INSTRUCTIONS WHICH MAY HAVE ADDITIONAL AND/OR ALTERNATIVE SERVICING REQUIREMENTS AND/OR SERVICING FREQUENCIES.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.