

Air Compressor - Medical

Last Issue Date: 28/11/2017		Type Of Service				
Activity		A	B	C	D	E
1	Turn off compressor and allow 3 minutes for system to settle.	Y	Y	Y		
2	Record hours run.	Y	Y	Y		
3	Record pressure gauge reading.	Y	Y	Y		
4	Check water level in separator.	Y	Y	Y		
5	Check and repair any water leaks.	Y	Y	Y		
6	Drain condensate from receiver using manual valve.	Y	Y	Y		
7	Operate and check automatic condensate drain valve.	Y	Y	Y		
8	Check for air leaks.		Y	Y		
9	Check tension of drive belts.		Y	Y		
10	Check air end oil level.		Y	Y		
11	ELECTRICAL: Check condition and operation of all electrical components including: a) All safety devices; b) All connections for security, tightness, contact and corrosion; c) Relays and contactors; d) All overloads and circuit breakers; e) All indicator lights; f) Compressor motor including motor current draw at full operating load and compare with rated input; and g) Fan motors.			Y		
12	Drain control line filter.			Y		
13	Inspect and clean enclosure filter.			Y		
14	Check scavenge oil flow (if applicable).			Y		
15	Check after cooler auto drain.			Y		
16	Clean scavenge line filter.			Y		
17	Clean air inlet filter element.			Y		
18	Externally clean oil / after cooler matrix.			Y		
19	Clean dirt & grease from compressor panels.			Y		
20	Clean surrounding area of rubbish etc.			Y		
21	Remove and dispose of all waste material.			Y		
22	Start compressor.	Y	Y	Y		
23	Record all the results in the log book.	Y	Y	Y		

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

A SERVICE DAILY

B SERVICE WEEKLY

C SERVICE 6 MONTHLY

CHECK THAT THE REGISTRATION IS CURRENT (WHERE APPLICABLE)
FOR UNITS WITH RECEIVERS ABOVE 150MPA INCLUDE INSPECTION
(ME240) AND REGISTRATION (ME171).

FOR THE TDS SPLIT VERSIONS REFER TO ME01D AND ME01C.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.