

Evaporative Cooler

Last Issue Date: 03/11/2020		Type Of Service				
Activity		A	B	C	D	E
1	ELECTRICAL: a) Carry out a visual inspection for obvious damage to the equipment. b) To the unit frame and pump shaft test the earthing continuity to AS3000 (hard wired). Note: The tests are to be done before and after isolation, and after re-instatement.		Y	Y	Y	
2	Check the condition of the unit, especially for signs of corrosion, wear and damage.		Y		Y	
3	Remove filter frames check and clean both filter pads and frames.		Y	Y	Y	
4	Empty water reservoir, clean basin thoroughly and refill with water to correct level. Ensure the water level does not rise above the basin lip.			Y	Y	
5	Check and clean water distribution channels.			Y	Y	
6	Check the float assembly for correct operation and level.			Y	Y	
7	Check water supply, especially for leaks.		Y	Y	Y	
8	Empty water reservoir and clean basin thoroughly. Leave empty during winter period.		Y			
9	Check operation of unit including: a) Controls. b) Thermostats. c) Blower shaft and motor bearings. d) Condition, alignment and tension of pulleys and V belts.				Y	
10	WATER PUMP: a) Check the water pump condition and operation (test run). b) Check the hose between the pump and water distributor for free running water. Replace any damaged or clogged up hoses. Note: Calcium build-up is common in areas with hard water (quality).			Y	Y	
11	Check and adjust bleed rate.			Y	Y	
12	Check ductwork including flexible connections, roof penetrations and selected access points in the vicinity of the moisture producing equipment and clean, check drainage facilities for condition and operation and where necessary clean drains.				Y	
13	Record the results in the logbook and submit a customer report to the FMSP.		Y	Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Special Comments and Technical Data

B SERVICE: END OF SEASON SERVICE DEPENDS ON SITE CONDITIONS.

C SERVICE 3 MONTHLY. (FOR EDUCATION, FIRST SERVICE IS EXPECTED TO BE UNDERTAKEN DURING THE SUMMER HOLIDAYS).

D SERVICE: IS A BEGINNING OF SEASON SERVICE, TIMING DEPENDS ON SITE CONDITIONS.

NOTE: IF UNITS OPERATE OVER 6 MONTHS MORE THAN ONE C SERVICE IS REQUIRED.

SERVICE ACTIVITIES AND FREQUENCIES MAY VARY DEPENDING ON SITE CONDITIONS AND MANUFACTURER'S RECOMMENDATIONS.

APPLICABLE LEGISLATION: MINISTERIAL BUILDING STANDARD MBS 002 - MAINTAINING THE PERFORMANCE OF ESSENTIAL SAFETY PROVISIONS, PUBLIC HEALTH (LEGIONELLA) REGULATIONS, AS3666.2.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.