

Air conditioner - Gas Engine Powered Multisplit

Last Issue Date: 10/05/2017		Type Of Service				
Activity		A	B	C	D	E
1	Indoor units: a) Check condition and operation of fan coil units. b) Clean coils. c) Clean filters. d) Clean condensate tray. e) Clean drain. Note: Each outdoor (condenser) unit services multiple indoor units, ensure they are all serviced and record quantity in service sheet.			Y	Y	Y
2	Gas engine: a) Check engine oil. b) Check engine filter. c) Check air cleaner element. d) Check ignition plug. e) Check valve clearance. f) Check cooling water. g) Check drain filter.				Y	Y
3	Check fuel gas hose.				Y	Y
4	Check V belt.				Y	Y
5	Check cooling water hose.				Y	Y
6	Outdoor Unit: a) Check compressor for refrigerant leaks and oil leaks. b) Check operating sound, vibration and sound insulation. c) Check for rust. d) Check filter box.				Y	Y
7	Check and replace if necessary: a) Oil. b) Oil filter. c) Air cleaner element. d) Ignition plug. e) Cooling water. f) Fuel gas hose. g) V-belt.				Y	Y
8	CONDENSER Check condition and operation of condenser, including: a) Coils for condition, cleanliness and obstructions. b) Fixings are secure. c) Condition and operation of fan, including controls. d) Clean condenser coil and its enclosure.				Y	Y
9	CONTROLS Check condition and operation of all controls including: a) Thermostats and set points.				Y	Y

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Air conditioner - Gas Engine Powered Multisplit

Last Issue Date: 10/05/2017		Type Of Service				
		A	B	C	D	E
Activity						
	b) Safety controls and devices.					
10	ELECTRICAL Check condition and operation of all electrical components including: a) All safety devices. b) All connections for security, tightness, contact and corrosion. c) Relays and contactors d) All overloads and circuit breakers e) All indicator lights f) Check compressor and fan motors				Y	Y
11	COMPRESSION TEST a) Carry out compression test on all cylinders. b) Check and adjust inlet and exhaust valves. If required. c) Perform 2nd compression test. Comparing results, ensure all cylinders are within manufacturer's recommendations.					Y
12	Check the gasket in the rocker bonnet cover before assembling.					Y
13	Remove and replace: a) Air filter. b) Compressor drive belt. c) Spark plugs.					Y
14	NEUTRALISER TANK a) Remove neutraliser tank. b) Remove neutraliser pallets. c) Wash the tank. d) Refill tank with new neutraliser pallets					Y
15	Record all results in log book.			Y	Y	Y

Special Comments and Technical Data

C SERVICE 6 MONTHLY, BUT MAY VARY DEPENDING ON SITE REQUIREMENTS.
 D SERVICE ANNUAL
 E SERVICE EVERY 10000 HOUR SERVICE OR 5 YEARS (WHICH EVER IS FIRST)
 NOTE: THE OUTDOOR UNIT SERVICES MULTIPLE INDOOR UNITS, ENSURE THEY ARE ALL SERVICED AND QUANTITIES RECORDED IN SERVICE SHEET.
 SERVICE FREQUENCIES AND ACTIVITIES MAY VARY DEPENDING ON SITE CONDITIONS AND MANUFACTURERS RECOMMENDATIONS.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full **Conditions of Use** provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 04/11/2021

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.