

Tanks - LPG (Above 250Kg/560L)

Last Issue Date: 04/11/2014		Type Of Service				
Activity		A	B	C	D	E
1	<p>TANK OWNERSHIP Determine whether tank is owned by gas supplier or site and record this on service sheet. The gas supplier's logo on the tank normally would indicate the tank is owned by the supplier. Do not undertake activity 2 if tank is owned by the supplier.</p>			Y	Y	
2	<p>Check condition and operation of:-(These services ONLY to be undertaken if tank is site owned) - valves,systems and instruments. - safety valves. - protection caps and discharge provisions. - fire protection equipment. - Check that the regulator incorporates over pressure protection.</p>			Y	Y	
3	<p>Check the area around storage handling station is maintained in a safe manner,in particular check:- - the area is clear of extraneous material. - vegetation which might become a fire hazard is kept short and other combustible material shall be kept clear within 3m of cylinders or tanks up to 8 cubic metres.</p>			Y	Y	
4	<p>Check condition of the surface coating of above ground tanks and for any alteration to the design colour.</p>				Y	
5	<p>Check signs and notices to ensure they are clearly legible and that the emergency contact numbers are correct. If emergency phone numbers is incorrect arrange rectification.Note the hotline phone number is not the emergency number.</p>				Y	
6	<p>Check compliance plate for details of next inspection date and record all details on a completed copy of the service report sheet. Notify of requirement for pending testing and inspection of tank immediately to the Superintendent.</p>				Y	
7	<p>10 Year inspection Site owned tanks - Facility Manager to arrange for the independent internal inspection of the tank to AS3788. Tanks not owned by the site - if inspection is due notify the site and note on the service sheet.</p>					Y
8	<p>Record all results in log book.</p>			Y	Y	Y

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia  
Department of Planning,  
Transport and Infrastructure

Download Date: 22/12/2020

## Special Comments and Technical Data

---

C SERVICE 6 MONTHLY

D SERVICE ANNUAL

E SERVICE 10 YEARS

TANKS SHALL BE INSPECTED IN ACCORDANCE WITH AS1596 AND THE REQUIREMENTS OF THE AUTHORITY AND DETAILS AS RECORDED ON THE COMPLIANCE PLATE.

THE EMERGENCY PHONE NUMBER TO BE DISPLAYED IS NOT THE HOTLINE NUMBER.

IF TANKS ARE OWNED BY THE GAS SUPPLIER DO NOT UNDERTAKE ACTIVITY 2.

SUPPLIER'S TANKS CAN BE IDENTIFIED BY THEIR LOGO ON THE TANK

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

*For more information please contact the applicable Facilities Management Service Provider.*



**Government of South Australia**  
Department of Planning,  
Transport and Infrastructure

**Download Date:** 22/12/2020

2 of 3

# Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.