

Reverse Osmosis Unit

Last Issue Date: 12/02/2020		Type Of Service				
		A	B	C	D	E
Activity		A	B	C	D	E
1	Change 5 micron filter cartridges if required. Refer Special Comments.			Y	Y	Y
2	Flush unit manually.			Y	Y	
3	Test product flow rate. *Clean system when product flow rate falls below 90% of design output.			Y	Y	
4	Check electrical conductivity and general water quality of product water. *Clean system when conductivity exceeds 10 micro siemens/cm.			Y	Y	
5	Clean the system. *Remove membranes from system and clean as per manufacturer's recommendations.				Y	
6	Check the condition and operation of the unit including: a) isolating switch and conduit for security of mounting. b) all controls. c) all safety devices. d) all connections for security, tightness, contact and corrosion. e) pumps. f) associated valves and pipework.				Y	
7	Ultra Violet Lamp, if applicable: a) check the condition and operation of the Ultra Violet Lamp. b) if required clean the tubes. c) if required, replace the lamps.				Y	
8	Record all readings and results in log book.			Y	Y	Y

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

C SERVICE 3 MONTHLY - 6 MONTHLY (DEFAULT ONLY). THE FREQUENCY OF THIS SERVICE WILL DEPEND ON THE MANUFACTURER'S RECOMMENDATIONS, THE WATER QUALITY AT THE SITE AND WHETHER THE INCOMING WATER IS TREATED. IN EXTREME CONDITIONS IT MAY BE NECESSARY TO REPLACE THE CARTRIDGE/S MONTHLY WHEREAS IN IDEAL CONDITIONS AND FOR CERTAIN MANUFACTURER'S UNITS THESE ACTIVITIES MAY NEED TO ONLY BE DONE ANNUALLY.

D SERVICE ANNUAL

E SERVICE FREQUENCY DEPENDS ON USAGE AND WATER QUALITY. REFER NOTE ABOVE.

FOR HEALTH CARE FACILITIES APPLICABLE STANDARDS ARE AS3551, AS4187 AND EN285. FOR WATER QUALITY REQUIREMENTS REFER TO AS4187 SECTION 7.2.3.1 AND APPENDIX GUIDANCE NOTE A7.2.3.1.

APPLICABLE LEGISLATION: PUBLIC HEALTH (GENERAL) REGULATIONS AND WH&S REGULATIONS.

WHERE SHUT DOWN OF SUPPLY IS REQUIRED FOR INSPECTION, TESTS, OR ANY MAINTENANCE WORK LIAISE WITH THE AGENCIES REPRESENTATIVE IN ARRANGING A SUITABLE TIME TO MINIMISE INTERFERENCE TO THE AGENCIES OPERATIONS.

A SPECIALIST CONTRACTOR IS REQUIRED FOR THIS TYPE OF SERVICE.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.