

Air Curtains/Air Transfer Hatches

Last Issue Date: 23/02/2018		Type Of Service				
Activity		A	B	C	D	E
1	STRUCTURAL INTEGRITY: Check the condition and security/integrity of the removeable S/S flange at the base of the unit to the wall or the supporting stands/posts as applicable.			Y	Y	
2	EXTERNAL (DIRTY ROOM) SIDE: Check the condition, integrity and operation of the unit, including: a) The perimeter silicon sealing or flange (as applicable) of the unit to the wall; b) The acrylic view panel and seals of the pass door; and c) The pass door handle, hinges and seals.			Y	Y	
3	INTERNAL (CLEAN ROOM) SIDE: Check the condition, integrity and operation of the unit, including: a) The perimeter silicon sealing or flange (as applicable) of the unit to the wall; b) The tempered glass view panel and seals of the pass door; c) The pass door handle, hinges and seals; and d) The interlock mechanism, checking that the integrity of the Internal (cleanroom) is maintained.			Y	Y	
4	Check the condition of the ULPA FILTER.			Y	Y	Y
5	Check the condition of the ULPA FILTER and replace when required. Frequency depends on the cleanliness of the ambient air and should be replaced once the Air Shower Pass Box is unable to deliver the rated airflow velocity (25m/s / 4921 fpm) and/or remove contaminants effectively. (default 3-5 years).					Y
6	Check the condition of the PRE-FILTER. Remove the air inlet grille and clean/wash/replace (as required) the filter (default 5-6 months).			Y	Y	
7	Check the S/S PERFORATED BASE to the chamber. Clean if necessary.			Y	Y	
8	Check the condition and operation of the UV LAMP (if fitted).			Y	Y	
9	Replace the UV LAMP (if fitted) annually (default). Check the operation and undertake surface decontamination afterwards.				Y	
10	CENTRIFUGAL MOTOR/FAN: a) Check the condition and for smooth, quiet, vibration free operation; b) Check the TIMER for fan running time is set correctly (adjustable between 0-60 seconds); and c) Clean the fan blades.			Y	Y	
11	Check the condition of the S/S NOZZLES and the operation ensuring high velocity air jets (25m/s / 4921 fpm) are directed within the chamber.			Y	Y	
12	ELECTRICAL: a) Check all connections; and b) Check the door indicator lights work correctly.			Y	Y	
13	Record the results in the logbook.			Y	Y	Y

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia  
Department of Planning,  
Transport and Infrastructure

Download Date: 04/11/2021

## Special Comments and Technical Data

---

C SERVICE 6 MONTHLY

D SERVICE ANNUALLY

E SERVICE 3-5 YEARS (DEFAULT - AS REQUIRED)

THE SERVICING ACTIVITIES AND FREQUENCIES MAY BE VARIED  
DEPENDING ON SITE CONDITIONS AND USER REQUIREMENTS.

THE SERVICING IS TO BE DONE IN ACCORDANCE WITH APPLICABLE  
STANDARDS AND THE MANUFACTURER'S RECOMMENDATIONS,  
REFER TO THE MANUAL FOR ADDITIONAL INFORMATION.

**Disclaimer** -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

*For more information please contact the applicable Facilities Management Service Provider.*



**Government of South Australia**  
Department of Planning,  
Transport and Infrastructure

**Download Date:** 04/11/2021

2 of 3

# Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.