

Exhaust System - Kitchen Hood (C & D Services)

Last Issue Date: 25/01/2018		Type Of Service				
Activity		A	B	C	D	E
1	<p>KITCHEN CANOPY / HOOD EXHAUST SYSTEM:</p> <p>a) Check the grese-arresting filters for excessive grease accumulation.</p> <p>b) Check the grease gutters for excessive grease accumulation.</p> <p>c) Check that the grease-arresting filters are secured in postion and free of any damage or deterioration.</p> <p>d) Check the internal surfaces of the hood and its exhaust plenum behind the filters for excessive grease accumulation. If there are any grease accumulations, ensure that air is not bypassing the filters.</p> <p>e) Clean grease-arresting filters as required. (eg. by steam cleaning or by high pressure hot water and detergent.)</p> <p>f) Check that any fixed fire protection systems are clean and unobstructed.</p> <p>g) Check the condition of the filter frames and frame supports, especially for signs of damage or deterioration.</p>			Y	Y	
2	<p>KITCHEN CANOPY/ HOOD EXHAUST SYSTEM:</p> <p>a) Clean the hood and its exhaust plenum.</p> <p>b) Check for excessive leaks and/or damage to grease-arresting filters and replace as necessary.</p> <p>NOTE: Non-metallic grease filters and other special types have to be replaced at specific time intervals whether damaged or not. In these cases, follow the manufacturer's instructions.</p> <p>c) Check the exhaust duct and access panels for accumulated grease and clean where necessary.</p>				Y	
3	<p>FAN, MOTOR AND DUCTING:</p> <p>a) Check that there are no physical obstructions likely to impede performance.</p> <p>b) Check the fan, motor and all bearings for noise, overheating and excessive vibrations. Check that they are secure.</p> <p>c) Check the condition and operation of the flexible connections (where fitted) for leaks, tearing or fraying.</p> <p>d) Check the fan belts for tension and wear (where applicable).</p> <p>e) Check that the condition of the casings, guards, impeller and other features is satisfactory.</p> <p>f) Clean the fan and motor if necessary.</p> <p>g) Check the lubrication of the bearings and lubricate where required.</p>			Y	Y	
4	<p>ELECTRICAL:</p> <p>a) Check that the isolating switch and conduit is secured into position.</p> <p>b) Check that all connections are securely in position.</p> <p>c) Check that condition and operation of all relays, contactors, overloads, circuit breakers, indicator lamps and any other safety devices.</p> <p>d) Check the continuity of the earth wiring.</p> <p>e) Record the operating motor's current draw and compare with the rated output.</p>				Y	
5	<p>OVERALL SYSTEM:</p> <p>a) Check the condition and operation of the system for general signs of damage, wear</p>			Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Exhaust System - Kitchen Hood (C & D Services)

Last Issue Date: 25/01/2018		Type Of Service				
		A	B	C	D	E
Activity						
	or corrosion. b) Check the overall performance of the plant.					
6	Record all results in the log book.			Y	Y	

Special Comments and Technical Data

C SERVICE THREE MONTHLY
 D SERVICE ANNUALLY
 REFER TO ME24B FOR THE B SERVICE.
 THIS SERVICE SLIT ONLY TO BE DONE ON APPROVED SITES.
 SERVICE ACTIVITIES AND FREQUENCIES MAY VARY DEPENDING ON
 SITE CONDITIONS, FREQUENCY OF USE AND/OR MANUFACTURER'S
 RECOMMENDATIONS.
 THIS TDS IS FOR COMMERCIAL-TYPE HOODS. FOR DOMESTIC HOODS,
 REFER TO ME24A.
 SERVICING IS TO COMPLY WITH AS1851.
 GREASE FROM FILTERS IS TO BE DISPOSED OF APPROPRIATELY
 TO MEET LOCAL AUTHORITY REQUIREMENTS.
 FIRE PROTECTION OR SUPPRESSION SYSTEMS INSTALLED WITHIN
 KITCHEN EXHAUST SYSTEMS MAY HAVE SPECIAL REQUIREMENTS
 REGARDING ADDITIONAL MANDATORY MAINTENANCE.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
 Department of Planning,
 Transport and Infrastructure

Download Date: 04/11/2021

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.