

Air & Dirt separator (Degassing unit)

Last Issue Date: 09/01/2018		Type Of Service				
Activity		A	B	C	D	E
1	<p>VACUUM FUNCTION TEST: Perform the vacuum test to ensure the proper functioning of the device. a) Check all screw fittings at the "VT" vacuum spray tube for leaks; b) Check the vents screw at the "PU" pump for leaks; and c) Check the "DV" degassing valve at the "VT" vacuum spray tube for leaks; and d) Check screw connections for leaks.</p>				Y	
2	<p>CLEAN THE DIRT TRAP: a) The "ST" dirt trap in the "DC" degassing line; b) Check the condition of the dirt traps e.g. mesh filter; and c) Clean all other dirt traps e.g. in the Fillset, (if applicable).</p>				Y	
3	Check the controller settings.				Y	
4	<p>Check the condition and operation of the degassing valves, especially: a) Connections for any signs of leaks; b) For damage or deterioration; and c) For secure fixing.</p>				Y	
5	Check the condition and operation of vacuum gauge.				Y	
6	Check the dirt-resistant motorised ball valve for any damage.				Y	
7	Check the displayed pressure. The required flow pressure is greater than or equal to 0.1 bar.				Y	
8	<p>PUMP: a) Check the condition and operation of pump, especially for signs of overheating, wear, corrosion and damage; and b) Check the condition and operation of associated valves and flexible connections, especially for deterioration or leaks.</p>				Y	
9	<p>ELECTRICAL: Check the condition and operation of all controls including: a) Isolating switch and conduit for security of mounting; b) All connections and conduits for security, tightness, contact and corrosion; c) Check earth wiring continuity; and d) Record motor operating current draw and compare with rated output.</p>				Y	
10	<p>UNDERTAKE A FUNCTION TEST: a) For "SE" system degassing; and b) For "NE" make-up degassing. Refer to the manual for information.</p>				Y	
11	Check the safety signage is correctly located.				Y	
12	Record all the results in the log book.				Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

D SERVICE ANNUALLY OR AT LEAST AFTER 16,000 DEGASSING INTERVALS WHICHEVER OCCURS FIRST.
SERVICING ACTIVITIES AND FREQUENCIES MAY VARY DEPENDING ON MANUFACTURERS RECOMMENDATION AND SITE CONDITIONS.
THE SERVICING MUST BE CARRIED OUT AND BY SPECIALIST PERSONNEL IN ACCORDANCE WITH THE MAINTENANCE MANUAL:
FOR THE VACUUM FUNCTION TEST, REFER TO CHAPTER 7.6.
FOR THE CLEANING OF THE DIRT TRAP, REFER TO CHAPTER 9.1.1.
FOR THE INSPECTION OF THE SYSTEM DEGASSING AND MAKE-UP DEGASSING, REFER TO CHAPTER 9.2.
BEFORE UNDERTAKING SERVICE WORK AT THE CONNECTIONS, ENSURE THAT THE SYSTEM IS DE-PRESSURISED.
PRESSURE VESSELS (IF APPLICABLE) MAY NEED TO BE REGISTERED WITH THE APPROPRIATE AUTHORITY. REFER TO AS4343 FOR INFORMATION AND HAZARD LEVEL.
THE "DC" DEGASSING LINE MUST BE CLEANED AFTER THE EXPIRY OF THE CONTINUOUS DEGASSING TIME AT THE LATEST AND THE DIRT TRAPS MUST BE CHECKED AFTER EVERY FILLING ACTION OR EXTENDED OPERATION.
THIS TDS IS FOR THE SERVICING OF DEGASSING UNITS AND DOES NOT COVER ANY OTHER COMPONENTS THAT MAY BE INSTALLED E.G. EXPANSION OR PRESSURE VESSELS, WATER SOFTENING OR TREATMENT UNITS ETC.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.