

Chemical Storage Cabinets

Last Issue Date: 28/10/2016		Type Of Service				
		A	B	C	D	E
Activity						
1	Undertake a visual inspection of the cabinet. Check there is no external damage to the panels or the hinges or the door catches.				Y	
2	Check the operation of the doors and that they open externally, are self-closing, close-fitting and held shut automatically by catches at two or more points. Check the condition of any seals or gaskets.				Y	
3	Check the operation of the hold-open door devices (if fitted).				Y	
4	Check that there is no damage or corrosion to the internal surfaces including the sump.				Y	
5	Check the cabinet signage is visible when the doors are closed. Required labelling is: - Name and address of manufacturer or distributor's details if made internationally; - Maximum capacity noted; and additional labelling as follows: For the storage of Corrosive Substances: - 'Class 8 Dangerous Goods' label at least 100mm wide. For the storage of Flammable and Combustible Liquids: - 'Class 3 Dangerous Goods' label at least 250mm wide and a sign 'NO SMOKING / NO IGNITION SOURCE WITHIN 3M' with words at least 50mm high.				Y	
6	If the cabinet is ventilated check that: - There are no vapours escaping into the room. Check the fan is located externally and check the integrity of the pipe ducting, especially the joints; - The exhaust runs continuously or whenever a person is in the area; - There is a 'loss of air flow' warning device; - The air intake grille is not obstructed or blocked; - The cabinet (flammable and combustible liquid storage) intake and exhaust flame arrestor duct connections are tight-fitting and undamaged; - The condition and operation of the fan for undue noise, vibration, damage, wear and corrosion; and - The electrical flexible cable and the plug top for damage or deterioration.				Y	
7	Record the results in the log book.				Y	

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

D SERVICE ANNUAL

THIS IS A GENERIC SERVICING SCHEDULE FOR THIS EQUIPMENT. THE SERVICING IS TO BE DONE IN ACCORDANCE WITH THE MANUFACTURERS WRITTEN INSTRUCTIONS WHICH MAY HAVE ADDITIONAL AND/OR ALTERNATIVE SERVICING REQUIREMENTS AND/OR FREQUENCIES.

FOR THE STORAGE OF DANGEROUS GOODS REFER TO THE:

- THE DANGEROUS GOODS (STORAGE & HANDLING) REGULATIONS 2000.
- AS1940, AS2243.10, AS3780, AS4326, AS2714, AS4452, AS3833.
- AS1216, AS1319 (SIGNAGE REQUIREMENTS).

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.