

Gas Detectors - Flammable Gases & Oxygen

Last Issue Date: 30/01/2020		Type Of Service				
Activity		A	B	C	D	E
1	Check: a) On system alarm conditions. b) Out of normal readings produced from the system. c) Where practicable, the cleanliness of detector heads. d) That the system is operating normally.			Y	Y	Y
2	a) A verification check shall be performed using the applicable certified gas corresponding to at least 40% of full scale concentration or as appropriate for the gas. For Oxygen use a certified concentration 20.9% by volume. b) Test gas/es shall be applied at the gas sensing elements of the system and the output from all readout devices incorporated in the system shall be noted. c) Where the system incorporates multiple measuring ranges, a verification check shall be performed on each measuring range. d) Where the system detects more than one gas, a verification check shall be performed for each of those gases. e) Where the system incorporates multiple sensing heads or sampling points, verification checks shall be conducted at each sensing head or sampling point. NOTE: At each readout device the output shall be within the accuracy requirements of this Standard for each test gas application.			Y	Y	Y
3	Test solenoid back-up battery and charging system (if applicable).			Y	Y	Y
4	a) The accredited test authority shall conduct a calibration of the equipment over its full operating range/s in accordance with that authority's terms of registration. The authority shall also verify the operation of all equipment functions with particular reference to alarm activation. b) Issue of a Calibration Certificate of Compliance covering the period to the next required examination by an accredited test authority.				Y	Y
5	Ensure shutdown of solenoid after gas calibration (if applicable).				Y	Y
6	If applicable replace the filter. Refer to the Special Comments for notes on servicing.				Y	Y
7	Replace gas sensor.					Y
8	Record all results in log book.			Y	Y	Y

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Special Comments and Technical Data

C SERVICE 3-6 MONTHLY DEPENDING ON MANUFACTURER'S RECOMMENDATIONS AND SITE CONDITIONS.

D SERVICE ANNUAL

E SERVICE EVERY 2 YEARS

NOTE: THOSE PARTS OF THE SYSTEM FAILING TO MEET THE ACCEPTANCE CRITERIA ARE TO BE IMMEDIATELY BE WITHDRAWN FROM SERVICE. THIS SHALL BE DONE IN A MANNER WHICH LEAVES THE SYSTEM IN AN OPERATIONAL CONDITION AS FAR AS PRACTICABLE AND WITH ONLY THOSE SYSTEM COMPONENTS WHICH CONFORM TO THE ACCEPTANCE CRITERIA STILL IN SERVICE.

THIS IS A GENERIC TDS. SERVICING AND CALIBRATION REQUIREMENTS MAY VARY DEPENDING ON THE MANUFACTURER'S RECOMMENDATIONS AND SITE CONDITIONS.

REFER TO AS60079.29.2 FOR ADDITIONAL INFORMATION.

FOR THE SECONDARY TDS FOR OXYGEN SENSOR CALIBRATION REFER TO ME76A.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.