

Fume Cupboard - Exhaust duct type

Activity		Type Of Service				
		A	B	C	D	E
Last Issue Date: 24/10/2016						
1	Check the condition and operation of air cleaning devices (if fitted) and maintain if required.	Y		Y	Y	
2	Perform a smoke test in accordance with AS2243.8.			Y	Y	
3	Perform a face velocity test in accordance with AS2243.8.			Y	Y	
4	Check condition and operation of fans, their motors, drives (including belts), bearings and lubricate where necessary.			Y	Y	
5	Check condition and operation of washdown facility (if fitted).			Y	Y	
6	Check condition and operation of the fire damper and the release mechanism (if fitted) and replace the fusible link if required.			Y	Y	
7	Check the operation of the fluorescent lamp (if fitted).			Y	Y	
8	Check the condition of the thermal detector and sprinkler heads (if fitted).			Y	Y	
9	Remove the baffles and clean them and the rear of the chamber.			Y	Y	
10	Wash the entire interior surface of the chamber, including the aerofoil (if fitted) with diluted detergent solution.				Y	
11	Check the condition of the services to the cupboard and ensure that all are correctly identified and operational.				Y	
12	Check the stability and condition of the discharge stack.				Y	
13	Check the condition of the exhaust ducting particularly the joints (where possible). Ensure the drain points are clear.				Y	
14	Check the make-up air balance.				Y	
15	Check the condition and satisfactory operation of the cupboard control system.				Y	
16	Check operation of the manual emergency isolator and isolation of services.				Y	
17	Check operation of the automatic emergency isolator by providing inadequate airflow conditions to the cupboard. *				Y	
18	Test the system for overall compliance with AS2243.8.				Y	
19	Attach a label to the cupboard with the date, inspector's name, report number, test result (pass or fail), and next due inspection date.				Y	
20	Record all the results in the log book.	Y		Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

A SERVICE WEEKLY BY THE SITE

C SERVICE SIX MONTHLY

D SERVICE ANNUALLY

* ACTIVITY 17 APPLIES TO FUME CUPBOARDS THAT HAVE CONTINUOUS MONITORING OF THE AIRFLOW.

THIS IS A GENERIC SERVICING SCHEDULE FOR THIS PLANT. THE SERVICING IS TO BE DONE IN ACCORDANCE WITH THE MANUFACTURERS WRITTEN INSTRUCTIONS WHICH MAY HAVE ADDITIONAL AND/OR ALTERNATIVE SERVICING REQUIREMENTS AND/OR FREQUENCIES.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

2 of 3

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.