

Switchboard - Mechanical Services

Last Issue Date: 04/05/2017		Type Of Service				
Activity		A	B	C	D	E
1	GENERAL: Check switchboard for: a) condition and any damage. b) ventilation. c) evidence of overheating. d) audible discharge. e) signs of vermin. f) combustible materials. g) general cleanliness.				Y	
2	INSULATION: Check condition of all insulation especially for: damage, cracks, signs of tracking or blistering, and any defects.				Y	
3	CONTACTORS: a) Check operation of all contactors, if applicable. b) Manually switch units on and observe operation.				Y	
4	CONTACTS: a) Check condition of contacts, especially for pitting or damage. b) Check operation of contacts, especially for backing springs pressure, contact and alignment, if applicable. c) Check operation of contacts by placing a voltmeter across the contacts, and observe voltage drop. (should be in the millivolt range).				Y	
5	MECHANISMS: Clean and check condition and operation of: a) mechanisms, especially rolling or sliding surfaces in the trip mechanism. b) all auxillary contacts, if applicable.				Y	
6	CONNECTIONS AND CABLE TERMINATIONS: Check all main electrical connections: a) for signs of overheating or verdigris. b) are tight and making good contact. c) Use heat sensitive detector to locate any hot spots or joints. Check main earthing for continuity and mechanical protection.				Y	
7	FUSES, CIRCUIT BREAKERS, SWITCHES AND SWITCH UNITS: a) Check condition, operation and for correct rating. b) Check circuit breaker orientation, all should be in the same position when off or on.				Y	
8	Check scheduling on the BMS.				Y	
9	Reset time switches/BMS to correspond with time changes due to the introduction of 'daylight saving' and reversion to 'normal' time.				Y	
10	Check: a) condition and operation of re-set buttons, re-set as necessary. b) condition and operation of all indicator lamps and switches.				Y	

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Switchboard - Mechanical Services

Last Issue Date: 04/05/2017		Type Of Service				
		A	B	C	D	E
Activity						
	c) all isolating switches are in the 'ON' operating position. d) all fascia switches are in the 'AUTO' operating position.					
11	Check all wiring duct covers are fitted.				Y	
12	Check and record delay periods of time delays cut-in and cut-out conditions on pressure and temperature controls.				Y	
13	Check motor overload settings and compare with normal motor ratings.				Y	
14	Check operation of motor overloads and circuit protection devices. Temporarily wind down overload setting to check tripping.				Y	
15	Check & record motors operating current draw and compare with ratings.				Y	
16	Where fitted, check cabinet cooling fans for correct operation & cleanliness. Check condition of filter media and clean if necessary.				Y	
17	ANTI-CONDENSATION HEATERS (if fitted): a) Check the condition and operation of the heater/s. b) Check the condition and operation of the thermostat/s.				Y	
18	Provide written report on checks, tests and findings.				Y	
19	Record all results in log book.				Y	

Special Comments and Technical Data

WHERE SHUT DOWN OF SUPPLY IS REQUIRED FOR INSPECTION AND TESTING PURPOSES LIAISE AND CO-OPERATE WITH THE CLIENT IN ARRANGING DATES AND TIMES TO REDUCE TO A MINIMUM INTERFERENCE TO THE CLIENT'S OPERATIONS.
ESTABLISH SAFE WORKING CONDITIONS FOR MAINTENANCE OF SWITCHBOARD, REFER TO AS2467.
IT IS THE RESPONSIBILITY OF PERSON/S IN CHARGE OF THE MAINTENANCE WORK THAT THE FOREGOING PROVISIONS ARE COMPLIED WITH AND THAT THE PERSONNEL CARRYING OUT THE WORK ARE FULLY CONVERSANT WITH THE NATURE AND EXTENT OF THE WORK TO BE DONE AND WITH THE LOCATION OF EQUIPMENT WHICH WILL REMAIN 'LIVE' DURING THE WORK.
D SERVICE ANNUAL
SERVICING IS TO BE DONE IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.
REFER TO AS3000 AND AS3439.1 FOR GENERAL INFORMATION.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.