

Shipping Container Freezer

Last Issue Date: 11/10/2019		Type Of Service				
Activity		A	B	C	D	E
1	TEMPERATURE: Check the temperature versus set point & record.		Y	Y	Y	
2	TEMPERATURE CONTROLS, check the: a) Condition & operation of the thermostat & the set points & recalibrate if necessary; b) Condition & operation of the Temperature Alarms; & c) Undertake a temperature running test (if applicable); d) Check the Controller for alarms, record and clear. If applicable: e) Partlow calibration chart - check for accurate recording & alarm function; f) HK controller systems - check the sensors for accuracy & grading.			Y	Y	
3	TEMPERATURE CALIBRATION, check the: a) Temperature versus set point and record. b) Accuracy of the indicated temperature with a calibrated thermometer. If the temperature variance is more than 1 degC recalibrate the temperature sensor. If the equipment cannot be recalibrated attach a tag stating the variance and notify the site representative and facility manager. See the Special Comments.				Y	
4	HAZARDS, check the: a) Floor for any slipping or tripping hazards; and b) Container for general housekeeping, including checking if the contents are dangerously stored, are located too closely to the air handling / evaporator unit/s, are obscuring signage, lighting or the duress alarm button.		Y	Y	Y	
5	DOORS: Check the door locking bar cams for a satisfactory opening & latching operation. NOTE: If there are any safety concerns undertake the appropriate action & notify the site representative & facility manager immediately. Refer Special Comments.		Y	Y	Y	
6	DOORS: a) Remove all dirt, grit & rust from the door hinges & locking bars; b) Lubricate the hinges with oil / lubricating spray; c) Lubricate the locking bar cams with grease; d) Check the condition of the rubber gasket seals and replace if they are cracked or perished. (default time is 10 years) & clean; & e) If the seals are heated check the operation is satisfactory.			Y	Y	
7	PRESSURE RELEASE VENT: a) If fitted, check the condition and for any leaks. b) Open the vent - if difficult check for ice.		Y	Y	Y	
8	INTERNAL LIGHTING: Check the Lighting and clean if required.		Y	Y	Y	
9	EMERGENCY LIGHTING SYSTEM: Not applicable for Containers. If installed - as a best practice feature: Check the condition and operation of the Emergency Lighting within the Container and clean if required. Refer Special Comments.		Y	Y	Y	
10	EXTERNAL INDICATOR LAMP FOR "OCCUPIED" CONTAINER:		Y	Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Shipping Container Freezer

Last Issue Date: 11/10/2019		Type Of Service				
Activity		A	B	C	D	E
	Check the Lamp is illuminated when the interior lights are on.					
11	<p>CONDITION VISUAL INSPECTION: Check the:</p> <p>a) Overall integrity and condition inspecting the key components including the door panels, vent/s, panels for any damage;</p> <p>b) Racks and/or shelves are secure and are undamaged;</p> <p>c) Drain hose is clear;</p> <p>d) Condensers and driers for corrosion;</p> <p>e) Caps and covers are fitted;</p> <p>f) Door & seal of the Control Box; and</p> <p>g) Controller, datacorder and battery packs are present.</p>			Y	Y	
12	Check the condition of the safety signage.		Y	Y	Y	
13	<p>DURESS BUTTON - ALARM SYSTEM:</p> <p>- Check the condition and operation of the Alarm.</p> <p>If applicable as this is a best practice feature & not obligatory:</p> <p>- Check the Alarm connection to the security / auto-dialler service. Refer Special Comments.</p>		Y	Y	Y	
14	<p>DURESS BUTTON ALARM SYSTEM:</p> <p>a) Take an Alarm sound pressure level measurement from 3m away & check it is a min. of 90dB(A); and</p> <p>b) Record the reading in the log book.</p>			Y	Y	
15	<p>EXTERNAL FLASHING BEACON:</p> <p>If applicable, this is a best practice feature & not obligatory:</p> <p>Check the condition and operation of the flashing beacon (or other) mounted outside the Container.</p>		Y	Y	Y	
16	<p>EVAPORATOR / AIR HANDLING UNIT:</p> <p>Check the condition & operation, including:</p> <p>a) Fans, pulleys & belts, especially for alignment, tension & wear;</p> <p>b) Evaporator coils, especially for cleanliness and obstructions;</p> <p>c) Check for any ice on the evaporator fins or pipes. If there is a build-up defrost check the defrosting system for any defects;</p> <p>d) Condensate trays and drains, including heaters if fitted;</p> <p>e) Check for any water on the floor. This may signify that an evaporator drainpipe is blocked; and</p> <p>f) Clean the coils as required.</p>		Y	Y	Y	
17	<p>REFRIGERANT SYSTEM, check for:</p> <p>a) Oil leaks;</p> <p>b) Refrigerant leaks at all joints and connectors;</p> <p>c) Correct compressor oil level;</p> <p>d) Correct moisture indicator and refrigerant charge level; &</p> <p>e) Record the refrigerant type, run hours and software version.</p>			Y	Y	
18	DEFROSTING OPERATION:			Y	Y	

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Shipping Container Freezer

Last Issue Date: 11/10/2019		Type Of Service				
Activity		A	B	C	D	E
	a) Check the defrost function - auto and manual. If applicable: b) Set the defrost time for 12 hours & ensure the vents are closed unless otherwise required; and c) Place the unit on to 'Auto Pre-trip' long version.					
19	Check for excessive noise & vibration while the unit is operating.			Y	Y	
20	ELECTRICAL: Check and record the current draw and electrical insulation of the: a) Compressor motor at full operating load and compare the draw with the rated output; b) Evaporator fan motors at low speed and high speed; c) Condenser fan motors; and d) Heater elements.			Y	Y	
21	ELECTRICAL: Check the dual voltage switch & operation (if applic).			Y	Y	
22	Check the emergency power supply, if applicable.			Y	Y	
23	ELECTRICAL: Check the condition & operation of all electrical components incl: a) All safety devices; b) Power cables and plugs; c) All connections for security, tightness, contact and corrosion; d) All relays and contactors; e) All overloads and circuit breakers; & f) All indicator lights.				Y	
24	INTERNAL PANEL CONDITION: Check the internal lining for any damage or movement, particularly the joints, ceiling/wall junction, wall/floor junction and door perimeter for complete sealing integrity.				Y	
25	EXTERNAL PANEL CONDITION: Check the external panelling including the roof for any rust, particularly at joints, vent openings, depressions etc. Remove rust from any areas, seal and paint (rust proof).					Y
26	Record the results in the log book.		Y	Y	Y	Y

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

Special Comments and Technical Data

B SERVICE MONTHLY
C SERVICE 6 MONTHLY
D SERVICE ANNUALLY
E SERVICE 5 YEARLY

CONTAINER FREEZERS ARE HIGH RISK PLANT IN TERMS OF SAFETY AND MAY ALSO BE HIGH RISK IN TERMS OF PERFORMANCE REQUIREMENTS/CONTROLS FOR TEMPERATURE.

IMMEDIATELY UNDERTAKE THE APPROPRIATE ACTION & ADVISE THE SITE REP. & FACILITY MANAGER OF ANY ISSUES.

PRIOR TO TESTING THE DURESS ALARM NOTIFY THE SITE REPRESENTATIVE / APPLICABLE STAFF.

THE SERVICE ACTIVITIES & FREQUENCIES ARE GENERIC & MAY NEED TO BE MODIFIED FOR THE SITE CONDITIONS, THE MANUFACTURER'S RECOMMENDATIONS &/OR PERFORMANCE REQUIREMENTS OF THE FREEZER. THIS NOTE IS PARTICULARLY RELEVANT TO ACTIVITIES 1 - 3 FOR THE MONITORING AND CONTROL OF THE TEMPERATURE VERSUS THE SET POINT & ANY VARIANCE MAY BE CRITICAL.

APPLICABLE LEGISLATION & STANDARDS: SA WH&S ACT & MINISTER'S SPEC. SA 76 (2015) & FOR FOOD STORAGE ALSO: SA FOOD ACT & FOOD SAFETY STDS. 3.1.1, 3.2.3, ASISO 22000.

ENSURE THE BREAKDOWN TECHNICIANS CONTACT DETAILS ARE WITH THE LOG BOOK & ALSO OUTSIDE THE CONTAINER. FOR CONSTANT TEMPERATURE ROOMS REFER TO ME88.

FOR COOLROOM/FREEZER ROOMS REFER TO ME89.

FOR: CONTROLLED ENV. RM: GROWTH - MECHANICAL - REFER ME189.

FOR: CONTROLLED ENV. RM: GROWTH - ELECTRICAL - REFER ME189C.

FOR: CONTROLLED ENV. ROOM: CHILLED GLYCOL - REFER ME189A.

FOR: CONT'D ENV. RM: REF. RACK COOL/FREEZER - REFER ME189B.

FOR THE EMERGENCY LIGHTING TDSs REFER TO THE F17 / F18 SUITES.

FOR THE DURESS ALARM TDS REFER TO ET30.

FOR SECONDARY & DISCRETIONARY TDS'S REFER TO:

- ME89E: SANITISATION / ME89F: CLEANING OF FAN UNITS.

Disclaimer -This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 04/11/2021

4 of 5

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.