

Backflow Prevention Devices

Last Issue Date: 07/10/2020		Type Of Service				
		A	B	C	D	E
Activity						
1	Ensure the area containing the device is clear of obstructions and has easy maintenance access.				Y	
2	Test for correct operation. Refer to the applicable Appendix in AS2845.3 depending on the type of backflow prevention device.				Y	
3	Check the condition of the device and associated valves and connections.				Y	
4	Check all associated valves and connections for leaks.				Y	
5	Check that the backflow prevention device is suitable for the current use in accordance with AS3500.1. Report the results in the service report and inform the FMSP if the device is NOT suitable for the current hazard level / use.				Y	
6	Record the results in the logbook and submit a customer service report to the FMSP.				Y	

Special Comments and Technical Data

D SERVICE ANNUAL

NOTE THE SERVICE DETAILS DEPEND ON THE TYPE OF BACKFLOW PREVENTION DEVICE. REFER TO AS3500.1, TABLE 4.4.1 FOR SUITABILITY OF DEVICES AND APPENDIX F FOR TYPES OF BACKFLOW PROTECTION. REFER TO THE APPROPRIATE APPENDIX IN AS2845.3. CHECK THAT THE INSTALLED DEVICE IS SUITABLE FOR THE CURRENT HAZARD LEVEL, REPORT THE RESULTS IN THE SERVICE REPORT AND NOTIFY THE FMSP IF THE DEVICE IS NOT SUITABLE.

THE TECHNICIAN IS TO COMPLETE THE MANDATORY, ANNUAL REPORT AND SUBMIT IT TO THE OFFICE OF THE TECHNICAL REGULATOR AND TO THE FMSP. THE TEST REPORT FORMAT MUST BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE OFFICE OF THE TECHNICAL REGULATOR. THE COMMISSION, INSPECTION & MAINTENANCE REPORT IS THE ONLY FORM THAT WILL BE ACCEPTED. IF COMPLETING THE FORM ELECTRONICALLY AND EMAILING IT BACK TO THE OTR, SAVE IT TO YOUR COMPUTER BEFORE FILLING IN THE FIELDS, THEN SAVE IT AGAIN BEFORE EMAILING IT OTHERWISE THE DATA MAY NOT BE RETAINED.

A COMPLETED REPORT AND A CERTIFICATE OF COMPLIANCE (IF APPLICABLE) MUST BE SENT TO THE OFFICE OF THE TECHNICAL REGULATOR BY THE TECHNICIAN WITHIN SEVEN DAYS OF COMPLETING THE WORK. WHEN COMPLETING THE REPORT, PLUMBERS MUST NOTE THAT:

1. ALL FIELDS ARE MANDATORY AND SHOULD BE COMPLETED BEFORE SUBMISSION.
2. THE LICENCE NUMBER QUOTED IS A PLUMBERS, GAS FITTERS AND ELECTRICIANS (PGE) NUMBER, NOT A BUILDING (BLD) NUMBER.

APPLICABLE LEGISLATION AND STANDARDS: OFFICE OF THE TECHNICAL REGULATOR UNDER THE WATER INDUSTRY REGULATIONS, AS 2845, AS3500.1.

Disclaimer - This TDS is intended to provide guidance only to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full [Conditions of Use](#) provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



Government of South Australia
Department of Planning,
Transport and Infrastructure

Download Date: 22/12/2020

Conditions of Use

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI [Agency Work Procedure Manual](#).

Users of a TDS should familiarise themselves with the following **Conditions of Use**:

1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
2. If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
4. You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the [Work Health and Safety Act 2012](#).
5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
8. DPTI may change information and data in a TDS without notice.
9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.