## In-Line Sewage Grinder

| Last Issue Date: 29/01/2008  Activity |  | Type Of Service |   |   |   |   |
|---------------------------------------|--|-----------------|---|---|---|---|
|                                       |  | Α               | В | С | D | E |
| 1                                     | Clean down chamber/pit, if open type.  |                 |   |   | Υ |   |
| 2                                     | Check condition of control panel and components.   |                 |   | Υ | Υ |   |
| 3                                     | Check control cable conduits from chamber/pit are correctly sealed to prevent ingress of sewer gas into controller.  |                 |   | Y | Y |   |
| 4                                     | Run and check operation of in-line grinder, including:-  * Sequence testing to confirm all control and alarm functions.  * Electrical check of:-  - windings integrity.  - insulation integrity.  - all indicator lights and alarms. |                 |   | Y | Y |   |
| 5                                     | Check condition of all internal surfaces, especially surface coatings integrity.   |                 |   | Y | Y |   |
| 6                                     | Check condition of: cutters mechanical seals lifting chains/cables and shackles cradle fixings.  |                 |   |   | Y |   |
| 7                                     | Check, clean, descale and grease frames and covers to ensure correct gas tight fitment.  |                 |   |   | Y |   |
| 8                                     | Provide written report on checks, tests and findings.  |                 |   |   | Υ |   |
| 9                                     | Record all results in log book.  |                 |   | Υ | Υ |   |

## **Special Comments and Technical Data**

- \* ESTABLISH SAFE WORKING CONDITIONS.
- \* SPECIALIST CONTRACTOR SUGGESTED FOR THIS TYPE OF WORK.
- \* ANY MAINTENANCE WORK TO BE PERFORMED ON SEWAGE GRINDER ETC WILL BE IDENTIFIED FROM THE SERVICE & CONDITION REPORTS.
- C SERVICE EVERY 6 MONTHS.

**Download Date: 22/12/2020** 

D SERVICE ANNUAL

**Disclaimer -**This TDS is intended to provide <u>guidance only</u> to support Preventative Maintenance servicing activities. All TDS users are encouraged to read and understand the full **Conditions of Use** provided on the final page of this document and on the DPTI website.

For more information please contact the applicable Facilities Management Service Provider.



1 of 2

## **Conditions of Use**

A TDS should be used as a generic guide for Facilities Management Service Providers (FMSP) to deliver Facilities Maintenance Services, specifically Preventative Maintenance in accordance with the DPTI *Agency Work Procedure Manual*.

Users of a TDS should familiarise themselves with the following Conditions of Use:

- 1. You use the information and data contained in any TDS published by DPTI at your sole risk. DPTI-AGFMA does not have the expertise to provide complete or accurate technical data schedules and provides these technical data sheets merely as a starting point and/or guide.
- If you rely on the information in a TDS you are responsible for ensuring, by independent verification, its accuracy, currency and completeness. DPTI cannot guarantee that the information contained in a TDS meets the standards or requirements of legislative requirements.
- 3. A TDS is not an exhaustive list of tasks or obligations that may be required and is generally generic in nature. DPTI does not oblige the user of a TDS to rely on it to the exclusion of other sources of information. For example, manufacturer's requirements may need to be followed for additional and / or alternative tasks and for additional and / or alternative servicing frequencies. You should always check the primary source of information such as the Australian Standards, manufacturer's specifications, legislation and other standards before undertaking any work to which a schedule may apply.
- You must apply appropriate risk management principles and carry out all tasks in accordance with obligations under the <u>Work Health and Safety Act 2012.</u>
- 5. You must not use a TDS unless you meet the specific competency requirements for preventative maintenance servicing works and are capable of applying the TDS to your trade or area of expertise. A TDS is only to be used by people who are specifically instructed by DPTI to use them and only for work undertaken in South Australia.
- 6. DPTI, its agents, instrumentalities, officers and employees make no representations, express or implied, as to the accuracy of the information, the data contained in a TDS or the suitability of a TDS for a particular purpose.
- 7. DPTI does not provide legal advice. DPTI accepts no liability, howsoever arising, for any loss resulting from the use of a TDS and any information or data or reliance placed on them.
- 8. DPTI may change information and data in a TDS without notice.
- 9. DPTI may revise this disclaimer at any time by updating these Conditions of Use.



For more information please contact the applicable Facilities Management Service Provider.

**Download Date: 22/12/2020** 

2 of 2